

## HSC1 Cupboard as part of the space

(1996)

### Reg. 7.3.1

Cupboards of less than 2 m<sup>2</sup> may be accepted as part of the space they serve provided they have open ventilation to this space and do not contain any materials or equipment of fire risk.

