

HSC3 Public spaces extending over 2 decks

(1996)

Reg. 7.4.4.1

Public spaces extending over 2 decks may be considered as one space, provided that

- the mean length and width of the opening area between lower and upper part is at least 25% of the mean length and width of the upper part of the whole space or at least of a corresponding area,
- sufficient means of escape is provided from both levels of the space directly leading to an adjacent safe area or compartment,
- the whole space is served by one section of sprinkler system with one relieve valve.

