

FTP 1 Adhesives used in A or B class divisions

(June
2000)

(FTP Code 3.1, Res A.754 para. 3.2.3)

Adhesives used in A or B Class divisions should be low flame spread.

Note: This UI FTP 1 is to be uniformly implemented by IACS Members and Associates from 1 January 2001.

