
SC119 Balancing ducts

(1996)

(Rev.1

Nov 2005)

(Reg. II-2/9.4.1.2 and Reg. II-2/9.4.2)

Balancing openings or ducts between two enclosed spaces are prohibited except for openings as permitted by Reg. II-2/9.4.1.2 and Reg. II-2/9.4.2.

