
SC130 Fire Detection and Sprinkler Systems in Refrigerated Chambers and Similar Spaces

(May, 1998)
(Rev.1
July 2004)
(Rev.2
Nov 2005)

(Reg. II-2/7.5.2 and Reg. II-2/10.6.1.1)

(Reg. II-2/41-2.5 as contained in MSC24(60), FSS Code, Ch. 8, 2.1.1)

Heat detectors are acceptable in refrigerated chambers and in other spaces where steam and fumes are produced such as saunas and laundries. Refrigerated chambers may be fitted with dry pipe sprinkler systems.

Note:

1. This Unified Interpretation is to be applied by all Members and Associates on ships contracted for construction on or after 1 January, 1999.
2. The “contracted for construction” date means the date on which the contract to build the vessel is signed between the prospective owner and the shipbuilder. For further details regarding the date of “contract for construction”, refer to IACS Procedural Requirement (PR) No. 29.

END