

---

# SC198 Sections in local application fire extinguishing systems

(June 2005)

(Reg.II-2/10.5.6.3)

## Regulation:

Fixed local application fire-extinguishing systems are to protect areas such as the following without the necessity of engine shutdown, personnel evacuation, or sealing of the spaces:

.1 the fire hazards portions of internal combustion machinery...

## Interpretation:

“In multi-engine installations, at least two sections should be arranged.”

---

## Note:

This UI is to be uniformly implemented by IACS Members and Associates on ships the keels of which are laid from 1 January 2006.

END