

**SC199**  
(June 2005)

## **Fire fighting systems in cargo sampling lockers**

(Reg.II-2/10.6.3.2)

### **Regulation:**

Flammable liquid lockers shall be protected by an appropriate fire-extinguishing arrangement approved by the Administration.

### **Interpretation:**

“The requirements given in SOLAS Reg. II-2/10.6.3.2. and 10.6.3.3 are not considered applicable for cargo service spaces intended for the stowage of cargo samples, when such spaces are positioned within the cargo area onboard tankers.”

---

### **Note:**

This UI is to be uniformly implemented by IACS Members and Associates on ships the keels of which are laid from 1 January 2006.

END