

---

# SC219 Fire Testing of Equivalent Water-Based Fire Extinguishing Systems (IMO MSC/Circ.1165, Appendix B, 4.5.4.1)

(Oct  
2007)

Regulation (IMO MSC/Circ.1165, Appendix B, 4.5.4.1)

#### 4.5.4 Duration of test

4.5.4.1 After ignition of all fuel sources, a 2-min preburn time is required before the extinguishing agent is discharged for the fuel tray fires and 5-15 s for the fuel spray and heptane fires and 30 s for the Class A fire test (Test No.7).

#### Interpretation

For flowing fire (Test No. 6), the 4 m<sup>2</sup> fire tray below the engine mock-up should be filled with a 50 mm water base and the 3 m<sup>2</sup> fire tray on top of the engine mock-up should be filled with a 40 mm water base. The fuel should be ignited when flowing down the side of the mock-up, approximately 1m below the notch. The pre-burn time should be measured from the ignition of the fuel.

---

#### Note:

This Unified Interpretation is to be applied by all Members and Associate for systems approved on or after 1 July 2008.

End of Document
--------------------