

## **SC34 Automatic sprinkler, fire detection and fire alarm system**

(Rev.1  
Nov 2005)

(FSS Code, Ch. 8, 2.5.2.3)

Nominal area is defined as being the gross, horizontal projection of the area to be covered.  
(*MSC/Circ. 1120*)



## **SC35 Fixed fire detection and fire alarm system**

(Rev.1  
Nov 2005)

(FSS Code, Ch. 9, 2.2)

The main (respective emergency) feeder shall run from the main (respective emergency) switchboard to the change-over switch without passing through any other distributing switchboard.



## **SC36 Arrangements for oil fuel, lubricating oil and other flammable oils**

Deleted in Nov 2005 because of SOLAS 2000 Amendments.



## **SC37 Arrangements for oil fuel, lubricating oil and other flammable oils**

(Corr.1  
2001)

Deleted in Nov 2005 because of SOLAS 2000 Amendments.

