

SC34 Automatic sprinkler, fire detection and fire alarm system

(Rev.1
Nov 2005)

(FSS Code, Ch. 8, 2.5.2.3)

Nominal area is defined as being the gross, horizontal projection of the area to be covered.
(*MSC/Circ. 1120*)



SC35 Fixed fire detection and fire alarm system

(Rev.1
Nov 2005)

(FSS Code, Ch. 9, 2.2)

The main (respective emergency) feeder shall run from the main (respective emergency) switchboard to the change-over switch without passing through any other distributing switchboard.



SC36 Arrangements for oil fuel, lubricating oil and other flammable oils

Deleted in Nov 2005 because of SOLAS 2000 Amendments.



SC37 Arrangements for oil fuel, lubricating oil and other flammable oils

(Corr.1
2001)

Deleted in Nov 2005 because of SOLAS 2000 Amendments.

