

## SC63 Pre-discharge alarm of fixed gas fire extinguishing systems

(Rev.1  
2001)  
(Rev.2  
Nov 2005)

(FSS Code, Ch. 5, 2.1.3.2)

The pre-discharge alarm shall be automatically activated, e.g. by opening of release cabinet door. An automatic time-delay device shall ensure that the alarm operates for at least 20sec. before the medium is released. (See also UI SC 25).

Reference is made to the Code on Alarms and Indicators (A1 Code), 1995 (resolution A.830 (19)).



---

## SC64 Fire dampers in ventilation ducts

(Rev.1  
Nov 2005)

(Reg. II-2/9.7.3.1)

Ducts or pipes with free sectional area of 0,075m<sup>2</sup> or less need not be fitted with fire damper at their passage through Class "A" divisions provided that the requirements of 9.7.2.1, 9.7.2.2, 9.4.1.1.8, 9.3.3 and 9.7.4.3 are complied with.



---

## SC65 Ventilation ducts for galley

(Rev.1  
2001)

Deleted in Nov 2005 because of SOLAS 2000 Amendments.



---

## SC66 Integrity of emergency generator space

Deleted in Nov 2005 because of SOLAS 2000 Amendments.

