
SC 162 Emergency fire pumps in cargo ships

(Feb. 2002)
(Rev.1
Nov 2005)

- General

(Reg. II-2/10.2.2.3.1.2)

Unless the two main fire pumps, their sea suction and the fuel supply or source of power for each pump are situated within compartments separated at least by A - O divisions, so that a fire in any one compartment will not render both fire pumps inoperable, an emergency fire pump should be fitted.

An arrangement in which one main fire pump is located in a compartment having more than one bulkhead or deck adjacent to the compartment containing the other main fire pump should also require an emergency fire pump.

