
SC44 Bulkheads within accommodation and service spaces

(1974)
(Rev.1
2001)

Deleted in Nov 2005 because of SOLAS 2000 Amendments.



SC45 Fire integrity of bulkheads and decks

(Rev.1
Nov 2005)

(Reg. II-2/9.2.3 and 9.2.4)

The following spaces are considered to belong to the categories of spaces dealt with by Reg. II-2/9.2.3 and 9.2.4, for the purpose of this regulation, as follows :

- Navigation equipment room (radar transmitter) and battery rooms (1): Control Stations

Note 1: Provision chambers are to be treated as store rooms.

Note 2: Refrigerated provision chambers are to be Category 9 service spaces if thermally insulated with combustible materials, or Category 5 service spaces if thermally insulated with non-combustible materials.



SC46 Protection of stairways and lift trunks in accommodation spaces, service spaces and control stations

(Rev.1
Dec 2005)

(Reg. II-2/9.2.3.4.1)

Dumb-waiters are to be regarded as lifts.

(MSC/Circ. 1120)

