
SC90 Bilge Drainage

(Rev.1
Nov 2005)

(Reg. II-2/19.3.5)

- a) Cargo spaces intended for carriage of flammable liquids with flash point less than 23 degrees C or toxic liquids shall be fitted with a fixed bilge drainage system independent or separated from the bilge system in machinery space and located outside of the machinery space.

If a single bilge drainage system completely independent of the machinery space is provided, the system is to comply with the Rule requirement to redundancy based on the size of the space or spaces which it services.

- b) Electrical equipment in the space containing bilge pumps serving cargo spaces intended for carriage of flammable or toxic liquids is to be according to unified interpretation SC79.



SC91 Personal Protection - Protective Clothing

(Rev.1
Dec 2005)

(Reg. II-2/19.3.6.1)

- a) The required protective clothing is for emergency purposes.
- b) For solid bulk cargoes the protective clothing is to satisfy the equipment requirements specified in Appendix E of the BC Code for the individual substances. For packaged goods the protective clothing is to satisfy the equipment requirements specified in emergency procedures (EmS) of the Supplement to IMDG Code for the individual substances.

(MSC/Circ. 1120)

